

篩分け試験

前回DATA読込 1-1 逆計算へ 篩分け試験 閉じる プリント出力

表題コピー

路線名 WWWWW 線
 箇所名 1111 市・郡 22222 町大字 3333 地内

篩 (mm)	55555555			66666666			77778888		
	残留重量 (g)	加積通過量 (g)	加積通過量 (%)	残留重量 (g)	加積通過量 (g)	加積通過量 (%)	残留重量 (g)	加積通過量 (g)	加積通過量 (%)
53.0									
37.5									
26.5									
19.0	0	232.7	100.0	0	246.9	100.0	0	280.6	100.0
9.50	4.9	227.8	97.9	15.1	231.8	93.9	12.6	268.0	95.5
4.75	10.2	217.6	93.5	15.6	216.2	87.6	16.3	251.7	89.7
2.00	17.9	199.7	85.8	27.9	188.3	76.3	24.7	227.0	80.9
0.85	22.3	177.4	76.2	35.3	153.0	62.0	32.3	194.7	69.4
0.425	23.5	153.9	66.1	35.8	117.2	47.5	35.6	159.1	56.7
0.250	20.7	133.2	57.2	29.1	88.1	35.7	28.3	130.8	46.6
0.106	44.7	88.5	38.0	49.1	39.0	15.8	55.8	75.0	26.7
0.075	25.8	62.7	26.9	26.9	12.1	4.9	29.5	45.5	16.2
受け皿に残った量	0.7			0.3			0.2		
洗滌による損失量	62.0			11.8			45.3		
下の皿に残った総量	62.7			12.1			45.5		
合計	232.7			246.9			280.6		

篩分け試験 逆算


路線名 WWWWW 線
 箇所名 1111 市・郡 22222 町大字 3333 地内

篩 (mm)	55555555			66666666			77778888		
	残留重量 (g)	加積通過量 (g)	加積通過量 (%)	残留重量 (g)	加積通過量 (g)	加積通過量 (%)	残留重量 (g)	加積通過量 (g)	加積通過量 (%)
53.0									
37.5									
26.5									
19.0	0.0	232.7	100	0.0	246.9	100	0.0	280.6	100
9.50	4.9	227.8	97.9	15.1	231.8	93.9	12.6	268.0	95.5
4.75	10.2	217.6	93.5	15.6	216.3	87.6	16.3	251.7	89.7
2.00	17.9	199.7	85.8	27.9	188.4	76.3	24.7	227.0	80.9
0.85	22.3	177.3	76.2	35.3	153.1	62	32.3	194.7	69.4



26.5									
19.0	0.0	232.7	100	0.0	246.9	100	0.0	280.6	100
9.50	4.9	227.8	97.9	15.1	231.8	93.9	12.6	268.0	95.5
4.75	10.2	217.6	93.5	15.6	216.3	87.6	16.3	251.7	89.7
2.00	17.9	199.7	85.8	27.9	188.4	76.3	24.7	227.0	80.9
0.85	22.3	177.3	76.2	35.3	153.1	62	32.3	194.7	69.4
0.425	23.5	153.8	66.1	35.8	117.3	47.5	35.6	159.1	56.7
0.250	20.7	133.1	57.2	29.1	88.1	35.7	28.3	130.8	46.6
0.106	44.7	88.4	38	49.1	39.0	15.8	55.8	74.9	26.7
0.075	25.8	62.6	26.9	26.9	12.1	4.9	29.5	45.5	16.2
受け皿に残った量	0.7			0.3			0.2		
洗滌による損失量	61.9			11.8			45.3		
下の皿に残った総量	62.6			12.1			45.5		
合計	232.7			246.9			280.6		

篩分け試験対数表




座標修正値

MESSAGE

篩 分 け 試 験

試験名	wwwwww									場所名	1111 市 22222 町大字 3333 地内								
	55555555						66666666			77778888									
篩	添重量	加排通過量		添重量	加排通過量		添重量	加排通過量											
(mm)	(g)	(g)	(%)	(g)	(g)	(%)	(g)	(g)	(%)										
33.0																			
37.5																			
25.0																			
19.0	0.0	232.7	100.0	0.0	246.9	100.0	0.0	280.6	100.0										
9.50	4.9	227.8	97.9	15.1	231.8	93.9	12.6	268.0	95.5										
4.75	10.2	217.6	93.5	15.6	216.2	87.6	16.3	251.7	89.7										
2.00	17.9	199.7	85.8	27.9	188.3	76.3	24.7	227.0	80.9										
0.85	22.3	177.4	76.2	35.3	153.0	62.0	32.3	194.7	69.4										
0.425	23.5	153.9	66.1	35.8	117.2	47.5	35.6	159.1	56.7										
0.250	20.7	133.2	57.2	29.1	88.1	35.7	28.3	130.8	46.6										
0.106	44.7	88.5	38.0	49.1	39.0	15.8	55.8	75.0	26.7										
0.075	25.8	62.7	26.9	26.9	12.1	4.9	29.5	45.5	16.2										
受皿に 残った 量	0.7			0.3			0.2												
洗 浄 に 残 る 量	62.0			11.8			45.3												
下 の 皿 に 残 り た 総 量	62.7			12.1			45.5												
合 計	232.7			246.9			280.6												

篩 分 け 試 験 対 数 表



0.075	0.106	0.25	0.425	0.75	2.00	4.75	9.50	19.0	25.0	27.5
シルト	砂						礫			

測 点	シルト (%)	砂 (%)	礫 (%)
55555555	26.9	58.9	14.2
66666666	4.9	71.4	23.7
77778888	16.2	64.7	19.1