

J G S 1 5 2 1	地盤の平板載荷試験（測定）	記録用紙（1 / 5）
------------------	---------------	-------------

調査件名 ○○地区地盤調査

試験年月日 1995. 07. 17

地点番号 （地盤高） S-1（AP. +2.55m）

試 験 者 ヒーシー・ネットワーク

載 荷 板 の 形 状			円形鋼板		載荷板の寸法 c m		Φ30 x t 2. 5		載荷板の面積 A m ²		7. 07x10-2	
ジャッキの種類			4 サイクルデータ		ジャッキの能力 k N		500		反力装置の種類		実荷重 (ハ	
載 荷 方 法			段階式繰返し載荷		荷重計の 校正係数 K k N/ m ² / 目盛		2. 78		天 候		晴れ	
サイ クル	荷重計の読み R	載 荷 圧 力 p = k R k N/ m ²	時 刻	経過時間 t min	変 位 計 の 読 み mm				変位計読み の 平 均 値 mm	累 計 沈 下 量 mm		
					1	2	3	4				
予 備 載 荷 ①			9: 31	0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00		
	0. 75	(10. 60)	9: 33	2	0. 40	0. 15	0. 06	0. 29	0. 23	0. 23		
	0. 00	(0. 00)	9: 35	4	0. 26	0. 15	0. 06	0. 16	0. 16	0. 16		
	0. 75	(10. 60)	9: 37	6	0. 43	0. 26	0. 17	0. 31	0. 29	0. 29		
	0. 00	(0. 00)	9: 39	8	0. 26	0. 25	0. 17	0. 17	0. 21	0. 21		
	0. 75	(10. 60)	9: 41	10	0. 41	0. 26	0. 17	0. 30	0. 29	0. 29		
	0. 00	(0. 00)	9: 43	12	0. 30	0. 26	0. 17	0. 20	0. 23	0. 23		
	0. 75	(10. 60)	9: 42	11	0. 43	0. 29	0. 19	0. 31	0. 31	0. 31		
	0. 00	(0. 00)	9: 46	15	0. 28	0. 28	0. 19	0. 20	0. 24	0. 24		
1 サ イ ク ル	1. 60	(22. 65)	9: 50	0	0. 31	0. 21	0. 18	0. 26	0. 24	0. 24		
			9: 51	1	0. 46	0. 37	0. 32	0. 41	0. 39	0. 39		
			9: 52	2	0. 49	0. 41	0. 36	0. 44	0. 42	0. 42		
			9: 55	5	0. 52	0. 43	0. 38	0. 45	0. 45	0. 45		
			10: 00	10	0. 56	0. 46	0. 40	0. 50	0. 48	0. 48		
			10: 05	15	0. 60	0. 48	0. 43	0. 54	0. 51	0. 51		
			10: 10	20	0. 60	0. 50	0. 45	0. 54	0. 52	0. 52		
			10: 15	25	0. 50	0. 50	0. 45	0. 54	0. 50	0. 50		
			10: 20	30	0. 60	0. 51	0. 45	0. 54	0. 52	0. 52		
	3. 00	(42. 46)	10: 21	0	1. 09	1. 07	0. 97	0. 98	1. 03	1. 03		
			10: 22	1	1. 33	1. 35	1. 23	1. 20	1. 28	1. 28		
			10: 23	2	1. 40	1. 41	1. 30	1. 26	1. 34	1. 34		
			10: 26	5	1. 47	1. 47	1. 35	1. 33	1. 41	1. 41		
			10: 31	10	1. 67	1. 54	1. 42	1. 49	1. 53	1. 53		
			10: 36	15	1. 68	1. 57	1. 46	1. 50	1. 55	1. 55		
			10: 41	20	1. 70	1. 59	1. 47	1. 51	1. 57	1. 57		
			10: 46	25	1. 71	1. 61	1. 49	1. 52	1. 58	1. 58		
10: 51			30	1. 72	1. 63	1. 51	1. 53	1. 60	1. 60			
除 荷 量	0. 10	(1. 42)	10: 52	0	1. 24	1. 33	1. 18	1. 08	1. 21	1. 21		
			10: 53	1	1. 19	1. 28	1. 13	1. 02	1. 15	1. 15		
			10: 54	2	1. 19	1. 28	1. 13	1. 02	1. 15	1. 15		
			10: 57	5	1. 17	1. 28	1. 12	1. 00	1. 14	1. 14		
2 サ イ ク ル	3. 00	(42. 46)	10: 58	0	1. 76	1. 67	1. 49	1. 50	1. 61	1. 61		
			10: 59	1	1. 80	1. 75	1. 56	1. 53	1. 66	1. 66		
			11: 00	2	1. 81	1. 77	1. 58	1. 53	1. 67	1. 67		
			11: 03	5	1. 82	1. 78	1. 59	1. 54	1. 68	1. 68		

特記事項 変位計番号と方位

（ジャッキ、力計、変位計の形式と容量気温など）
 分離式オイルジャッキ最大300kNロードセル200 kN デジタルゲージストローク50mm

[1kN/m² ≒ 0.0102 kgf/cm²]