

調査件名 ○○地区地盤調査

試験年月日 1995.07.17

地点番号（地盤高） S-1（AP. +2.55m）

試験者 ヒーシー・ネットワーク

載 荷 板 の 形 状			円形鋼板		載荷板の寸法 c m		Φ30 x t 2.5		載荷板の面積 A m ²		7.07x10-2	
ジャ ッ キ の 種 類			4 サイクルデータ		ジャッキの能力 k N		500		反力装置の種類		実荷重 (ハ	
載 荷 方 法			段階式繰返し載荷		荷重計の 校正係数 K kN/m ² /目盛		2.78		天 候		晴れ	
サイ クル	荷重計の読み R	載荷圧力 $p = k R$ k N/ m ²	時 刻	経過時間 t min	変 位 計 の 読 み mm				変位計読み の 平 均 値 mm	累計沈下量 mm		
					1	2	3	4				
除 荷 量	0.10	(1.42)	15:04	0	21.48	20.39	20.12	20.83	20.71	20.71		
			15:05	1	21.22	20.18	19.90	20.53	20.46	20.46		
			15:06	2	21.15	20.11	19.83	20.47	20.39	20.39		
			15:09	5	21.09	20.05	19.76	20.41	20.33	20.33		

特記事項

変位計番号と方位

(ジャッキ、力計、変位計の形式と容量気温など)
分離式オイルジャッキ最大300kNロードセル200 kN デジタルゲージストローク50mm